



City of National City Fire Department

Phone (619) 336-4550



Fire Department Fire Flow Requirements

Date: July 12, 2022
Project: Fire Flow All Projects
Reviews: R. Hernandez/Fire Marshal

Approval for final sign-off shall be contingent upon final field inspection and compliance with all applicable codes and ordinances. Allow for one week for processing. **FIRE FLOW LETTER SHALL BE REQUESTED EARLY IN THE PROJECT IN ORDER TO IDENTIFY POTENTIAL WATER DEFICIENCIES INTENDED FOR THE PROJECT**

A “Fire Flow” letter shall be required for all buildings in this jurisdiction. The procedure for determining fire-flow requirements for buildings or portions of buildings hereafter constructed shall be in accordance with this chapter (Appendix B Table B105.1 (2) *MINIMUM REQUIRED FIRE-FLOW AND FLOW DURATION FOR BUILDINGS*).

The following information is required for all fire flow letters:

- Applicant Name and Mailing Address
- Address of Site
- Parcel (APN) Number
- Building Construction Type
- Total Square Footage

A flow letter is provided free of charge and it shall take a minimum of (1) week to complete

Note: AHJ Approved sprinkler plans will not be released without the request and process of all flow letters through Sweetwater Authority from the National City Fire Department.

Revision: July 12, 2022
R.H.